



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

| CITY OF COALINGA FIRE DEPARTMENT | | |
|----------------------------------|--|-------------------------------|
| FIRE PREVENTION STANDARD | | |
| STANDARD TITLE: | 401.017 LUMINOUS EGRESS PATH MARKINGS SPECIFICATIONS | |
| STANDARD NUMBER: 401.017 | EFFECTIVE DATE: 1 October 2022 | REVISION DATE: 1 October 2022 |

PURPOSE

This policy has been established to clarify the requirements for the preparation and submission of all luminous egress path markings installation plans.

APPLICATION

This policy applies to contractors submitting luminous egress path markings plans to the Fresno Fire Department (FFD or Department) for review and approval.

OPERATIONAL POLICY

Based upon the need for uniformity in application across the Department's diverse service delivery area, and after careful deliberation, the Department has determined the following:

1. Submit a minimum of three (3) copies of the complete plan set.
2. Each of the following items shall be included on the plan submittal (these items will be verified at the counter). Plans will be rejected when not present:
 - a. The name of owner or occupant of the building.
 - b. Name, address, and contact information for the installing contractor.
 - c. Location of the project, including the City of Fresno officially assigned address and the building permit number.
 - d. A site plan of the location. A site plan shall show the layout of the building relative to public streets and private drives. A location pin from mapping software does not meet the requirements of a site plan.
 - e. The California Building Code occupancy group of the building.
 - f. The number of stories in the building.



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

| CITY OF COALINGA FIRE DEPARTMENT | | |
|----------------------------------|--|-------------------------------|
| FIRE PREVENTION STANDARD | | |
| STANDARD TITLE: | 401.017 LUMINOUS EGRESS PATH MARKINGS SPECIFICATIONS | |
| STANDARD NUMBER: 401.017 | EFFECTIVE DATE: 1 October 2022 | REVISION DATE: 1 October 2022 |

- g. The number of stairwells in the building.
 - h. The installation option being used.
 - i. Option 1 (allowed for buildings built before January 1, 2012)
 - ii. Option 2 (allowed for buildings built before January 1, 2012)
 - iii. CFC 1025 compliant (required for building built after December 31, 2011)
 - i. A floor plan on each story of the building that clearly indicates the location of the stairwells. If multiple stories of the building have the same floor plan, a single floor plan can be used and labeled "typical of floors X through X".
 - j. Manufacturer's specification sheets for each type of materials used in the installation.
3. The plans shall be drawn on a minimum of 11-inch x 17-inch paper.
4. Plans shall indicate how the markings will be installed on the following exit components:
- a. Steps
 - b. Landings
 - c. Handrails
 - d. Perimeter demarcation lines
 - i. Floor-mounted
 - ii. Wall-mounted
 - iii. Transition
 - e. Obstacles
 - f. Doors within the exit path
 - i. Emergency exit symbols
 - ii. Door hardware
 - iii. Door frames (to include doors leading into the stairwells)

OPERATIONAL GUIDELINE

This section intentionally left blank.



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

| CITY OF COALINGA FIRE DEPARTMENT | | |
|----------------------------------|--|-------------------------------|
| FIRE PREVENTION STANDARD | | |
| STANDARD TITLE: | 401.017 LUMINOUS EGRESS PATH MARKINGS SPECIFICATIONS | |
| STANDARD NUMBER: 401.017 | EFFECTIVE DATE: 1 October 2022 | REVISION DATE: 1 October 2022 |

PROCESS

This section intentionally left blank.

INFORMATION

As noted in the *California Fire Code (CFC)*, the fire code official has the authority to formulate policies they deem necessary based upon local conditions related to plan submittals for all systems and installations.

DEFINITIONS

This section intentionally left blank.

CROSS REFERENCES

California Building Code

Chapter 10, Means of Egress

California Fire Code

Section 1025, Luminous Egress Path Markings

Fresno Municipal Code

Section 10-51025, Luminous Egress Path Markings

Fire Prevention Manual

Section 402.017 Luminous Egress Path Marking