



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

CITY OF COALINGA FIRE DEPARTMENT		
FIRE PREVENTION STANDARD		
STANDARD TITLE:	FIRE EXTINGUISHING SYSTEM REQUIREMENTS PRE-PIPE INSP.	
STANDARD NUMBER: 405.002	EFFECTIVE DATE: March 15, 2022	REVISION DATE: March 15, 2022

PURPOSE

This policy has been established to provide direction for fire sprinkler contractors regarding required inspections of metallic fire sprinkler system piping, prior to the installation of the piping.

APPLICATION

This policy applies to the Coalinga Fire Department (CFD or Department) requirements for pre-pipe inspections for metallic fire sprinkler system piping. These requirements apply to both voluntary and required systems.

OPERATIONAL POLICY

As noted in the California Fire Code (CFC), Section 106, the fire code official has the authority to conduct inspections of fire related construction and components as a condition of issuing a construction permit.

Based upon the need for uniformity in application across the Department's service delivery area, the Department has determined the following:

1. All new metallic fire sprinkler piping, which has welds in it, and is utilized for fire sprinkler systems, must be inspected by fire department personnel prior to installation. These pre-installation inspections are to ensure that welding, cutting, drilling, etc., was carried out in compliance with the requirements found in National Fire Protection Association (NFPA) 13 – Automatic Sprinkler Systems (2016 ed. with California Amendments).
2. Prior to this inspection, it is the contractor's responsibility to verify that all discs, coupons, wire, and other debris has been removed from the piping. Contractors will also verify that the interior of all outlets are smooth, any slag or other welding residue (including wire) has been removed and the outlet deburred. Finally, contractors will confirm that no debris remains in the piping which would reduce the pressure and volume of water during fire sprinkler system activation.



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

CITY OF COALINGA FIRE DEPARTMENT		
FIRE PREVENTION STANDARD		
STANDARD TITLE:	FIRE EXTINGUISHING SYSTEM REQUIREMENTS PRE-PIPE INSP.	
STANDARD NUMBER: 405.002	EFFECTIVE DATE: March 15, 2022	REVISION DATE: March 15, 2022

3. All metallic piping that has been installed without a pre-pipe inspection will be required to be removed and inspected prior to any other inspections of the system by fire department personnel.
4. Contractors that install metallic piping without a pre-pie inspection will be subject to a penalty as noted in the City of Coalinga Master Fee Schedule.
5. Contractors that repeatedly violate this policy may be subject to additional administrative action(s) including complaints filed with the California Contractors State License Board, the refusal to issue new construction permits as authorized by CFC, Section 102.9, and any other remedy provided for by law may also be instituted at the sole discretion of the Department, and are not subject to appeal, except as noted by law.

OPERATIONAL GUIDELINE

This section left intentionally blank.

PROCESS

This section left intentionally blank.

INFORMATION

This section intentionally left blank.

DEFINITIONS

This section left intentionally blank.

CROSS REFERENCES

California Fire Code

Section 106, Inspections

Section 102.9, Matters not provided for

NFPA 13

Automatic Sprinkler Systems (2019 ed. With California amendments)