



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

CITY OF COALINGA FIRE DEPARTMENT		
FIRE PREVENTION STANDARD		
STANDARD TITLE:	405.023 SUPERVISORY/TROUBLE SIGNAL DISPOSITION	
STANDARD NUMBER: 405.023	EFFECTIVE DATE: October 26, 2022	REVISION DATE: October 26, 2022

PURPOSE

The purpose of this policy is to clarify the Coalinga Fire Department's (CFD or Department) requirements related to supervisory and trouble signals generated from fire alarm or fire sprinkler systems.

This policy is separate from, but should be considered in conjunction with, Fire Prevention Manual, Section 405.004, Disposition of Water Flow Signals.

APPLICATION

This policy applies to the Department's requirements for supervisory/trouble signal disposition.

OPERATIONAL POLICY

This section intentionally left blank.

OPERATIONAL GUIDELINE

Based upon the applicable code requirements, the Department has determined that:

Where a supervisory signal is generated from a fire alarm or fire sprinkler system, the central or supervising station, fire alarm monitoring company, etc., is no longer required to contact the Department's dispatch center to report the condition. Examples of supervisory signals include Valve tamper, Fire pump running, Low air pressure, etc.

Additionally, where a trouble signal is generated from a fire alarm or fire sprinkler system, the central or supervising station, fire alarm monitoring company, etc., is no longer required to contact the Department's dispatch center to report the condition.

Examples of trouble signals include Smoke detector missing, Low battery, Printer malfunction, etc.

These requirements apply to both required and voluntary systems, as well as new and existing fire alarm installations.



COALINGA FIRE DEPARTMENT

GREG DUPUIS, FIRE CHIEF

300 W. Elm Ave • Coalinga, CA 93210 • Phone (559) 935-1652 • Fax (559) 935-1638

CITY OF COALINGA FIRE DEPARTMENT		
FIRE PREVENTION STANDARD		
STANDARD TITLE:	405.023 SUPERVISORY/TROUBLE SIGNAL DISPOSITION	
STANDARD NUMBER: 405.023	EFFECTIVE DATE: October 26, 2022	REVISION DATE: October 26, 2022

PROCESS

This section left intentionally blank.

INFORMATION

In the past, the Department has required central and supervising stations, fire alarm monitoring companies, etc., to notify the Department's dispatch center when a supervisory or trouble signal was received from a protected premise.

Once notified, on duty Department staff would respond to the location to investigate the source of the signal and take appropriate action.

After careful deliberation, the Department has modified this policy to reflect the on- duty resources available, and to become consistent with other major jurisdictions within the State.

DEFINITIONS

This section left intentionally blank.

CROSS REFERENCES

Fire Prevention Manual

Section 405.004, Disposition of Water Flow Signals